



# GUWAHATI MUNICIPAL CORPORATION WATER WORKS :: PANBAZAR GUWAHATI-781001

## DETAILED TENDER NOTICE & BID DOCUMENTS

NAME OF WORK:- 2 nos. of raw water pump sets for Supply, Installation, Testing and Commissioning of electrical motor driven Horizontal Multistage (10 stage) centrifugal pump (220 H.P.) having efficiency not less than 73% with rated impeller dia not less than 271mm, coupled with TEFC squirrel cage foot mounted induction motor suitable for operation with 415 (+/- 10%) V, 3 phase power supply with star-delta starter at 2nd Stage Pumping Station along with common distribution panel board under Kamakhya Water Supply Scheme.

Issued against document fee payment receipt no. ....

Name of Tenderer:

---

Issue Date: .....

Issued To: .....

Full Postal Address:.....  
.....  
.....  
.....  
.....

Fax No. : ..... Tel No. :  
.....

Mobile No. : ..... E-mail : .....

Reference of cost of Tender Document:

Receipt no-- ..... Date-.....

**OFFICE OF THE GUWAHATI MUNICIPAL CORPORATION**  
**Water Works ::: Panbazar ::: Guwahati-1.**

**NAME OF WORK:-** 2 nos. of raw water pump sets for Supply, Installation, Testing and Commissioning of electrical motor driven Horizontal Multistage (10 stage) centrifugal pump (220 H.P.) having efficiency not less than 73% with rated impeller dia not less than 271mm, coupled with TEFC squirrel cage foot mounted induction motor suitable for operation with 415 (+/- 10%) V, 3 phase power supply with star-delta starter at 2nd Stage Pumping Station along with common distribution panel board under Kamakhya Water Supply Scheme.

**SCHEDULE FOR BID PROCEDURE**

SALE OF BID DOCUMENTS	FROM 06/12/2017 TO 11/12/2017
SUBMISSION OF BIDS	UP TO 14.00 HOURS OF 11/12/2017
START DATE OF BID	14.00 HOURS OF 06/12/2017
END DATE OF BIDS	14.00 HOURS OF 11/12/2017
OPENING OF BIDS	12/12/2017 AT 15.00 HOURS
PLACE OF OPENING OF BID	CONFERENCE HALL, GUWAHATI MUNICIPAL CORPORATION, PANBAZAR, GUWAHATI-01
OFFICER INVITING BID	COMMISSIONER, GUWAHATI MUNICIPAL CORPORATION, PANBAZAR, GUWAHATI-01



## OFFICE OF THE GUWAHATI MUNICIPAL CORPORATION

Water Works Wing :: Panbazar :: Guwahati-1.

No: GWS/185/2017/937

Date: - 05/12/2017

### **INVITATION FOR BID (RE BIDDING)**

The Commissioner, Guwahati Municipal Corporation, Guwahati invites fresh bids for the following work having experience of similar nature of work.

Details of the bid may be seen at e-procurement portal website i.e. [www.assamtenders.gov.in](http://www.assamtenders.gov.in) and also in the office of the undersigned during the office hours from 14.00 hours of 06/12/2017 to 14.00 hours of 11/12/2017.

The bidders must be enrolled in [www.assamtenders.gov.in](http://www.assamtenders.gov.in)

Sl. No.	Name of the work	Amount (in Rs.)	Bid Security (in Rs.)		Cost of bid documents	Period of completion
			For General	For SC/ST/OBC /UEE		
1	2 nos. of raw water pump sets for Supply, Installation, Testing and Commissioning of electrical motor driven Horizontal Multistage (10 stage) centrifugal pump (220 H.P.) having efficiency not less than 73% with rated impeller dia not less than 271mm, coupled with TEFC squirrel cage foot mounted induction motor suitable for operation with 415 (+/- 10%) V, 3 phase power supply with star-delta starter at 2nd Stage Pumping Station along with common distribution panel board under Kamakhya Water Supply Scheme	54,67,326.00	1,09,347.00	54,673.00	2,000.00	3 months

**Note:**

1. Online mode of submission of both Technical and Financial Bid is mandatory. Manual submission of Bid will not be accepted.
2. In the event of date of bid opening being a holiday, the activities will take place on the next working day.
3. Original copy of the following documents must be submitted on or before 11/12/2017 upto 14.00 hours at the office chamber of the undersigned.
  - (a) Original Power of Attorney for signing of Bid.
  - (b) Bid securities in the form of TDR/FDR from a nationalized/scheduled bank.
  - (c) Demand Draft/Banker's Cheque on any nationalized/scheduled bank for Rs. 2,000.00 as above in favour of "The Commissioner, Guwahati Municipal Corporation" towards cost of bid document for the job.
4. A hard copy of the technical bid submitted online is to be submitted on or before 11/12/2017 upto 14.00 hours for evaluation purpose. For any discrepancy between the online bid and the hard copy of the bid, the online bid will be governed and will be considered for evaluation.

5. Bidders are advised to scan their Technical Papers at 100dpi (in black & white mode) in 'pdf' format for multiple pages with maximum file size of 25 MB. If numbers of pages exceeds, the bidders are advised to create multiple files and upload the same in "Upload Additional Document" stage.
6. All the interested bidders are requested to read the bid document carefully before submission of their bid.

Sd/-  
Commissioner  
Guwahati Municipal Corporation  
Guwahati

Memo No: GWS/185/2017/937

-A

Date: - 05/12/2017

Copy to: -

1. The Municipal Secretary, GMC for appraisal of the Hon'ble Mayor, GMC & Member's of Mayor-in-council.
2. The C.A. & A.O., GMC for information.
3. The Director of Information & Public Relation Officer, Assam, Dispur, Last Gate, Guwahati for publication of the above NIQ in two English & one Assamese daily newspaper preferably in a) The Assam Tribune, b) The Sentinel & c) Amar Asom.
4. The Director of Information & Public Relation Officer, Kamrup (M), Panbazar, Guwahati-1 for publication of the above NIQ in two English & one Assamese daily newspaper preferably in a) The Assam Tribune, b) The Sentinel & c) Amar Asom.
5. Software Developer, GMC for uploading in the GMC portal.
6. Notice Board.
7. File.

Sd/-  
Commissioner  
Guwahati Municipal Corporation  
Guwahati



**OFFICE OF THE GUWAHATI MUNICIPAL CORPORATION  
PANBAZAR :: GUWAHATI-1.**

No: GWS/185/2017/937

Date: - 05/12/2017

**DETAILED TENDER NOTICE (RE-TENDER)**

Sealed tenders for “2 nos. of raw water pump sets for Supply, Installation, Testing and Commissioning of electrical motor driven Horizontal Multistage (10 stage) centrifugal pump (220 H.P.) having efficiency not less than 73% with rated impeller dia not less than 271mm, coupled with TEFC squirrel cage foot mounted induction motor suitable for operation with 415 (+/- 10%) V, 3 phase power supply with star-delta starter at 2<sup>nd</sup> Stage Pumping Station along with common distribution panel board under Kamakhya Water Supply Scheme” is invited from manufacturer or authorized dealer of the manufacturer or experienced and resourceful supplier having experience in *similar nature of works* and will be received at the Water Works Wing, Guwahati Municipal Corporation, Panbazar, Guwahati-01 up to 14.00 hours on **11/12/2017**.

Eligibility Criteria: - Tender(s) should satisfy the following eligibility criteria: -

<i>Sl. No.</i>	<i>Particulars</i>	<i>Amount</i>
1.	<i>Annual Turnover during last 3 (three) years ending 31-03-2017 (supported by authenticated documents)</i>	<i>150% of the tendered value of the work.</i>
2.	<i>Experience in similar nature of work completed successfully during last 5 (five) years shall be either of the following – (meaning of similar nature is defined in clause 15 of terms &amp; conditions)</i> <i>a. One similar completed work –</i> <i>b. Two similar completed work –</i> <i>c. Three similar completed work –</i>	<i>80% of the tender value of the work.</i> <i>50% of the tender value of the work.</i> <i>40% of the tender value of the work.</i>

**GENERAL INSTRUCTIONS TO THE TENDERERS**

The intending tenderers are requested to purchase the tender document from the Office of Water Works Wing, Panbazar, Guwahati by paying Rs.2,000.00 (Rupees Two Thousand) only in cash, to be paid to the Cashier, G.M.C. as document fee and submit their tenders in sealed covers at the place and within the date & time as indicated in the brief Notice Inviting Tender after signing & putting seals on each page and furnishing information & documents as required as per tender document. The tenderers are requested not to make any change(s) in the tender conditions / specifications other than the entries required for submission of tenders. In the event any change(s) are found in the documents after opening, the tender(s) will be liable for rejection.

Tenderers are advised to read the Tender document thoroughly and satisfy himself about the scope, terms & conditions etc. before submission of the bid.

It is imperative for each tenderer to familiarize all local condition and factors, which may have any effect on the execution of work covered under this tender document. In his own interest, the tenders are requested to familiarize themselves with Indian Income Tax Act, 1961, Indian Companies Act 1956, Indian Customs Act 1962, Assam Value Added Tax Act (VAT) and other related acts and laws and regulations with their latest amendments, as applicable. It must be understood and agreed that all such factors have properly been investigated and considered while submitting the tender. No claim for financial or any other adjustments to value of contract will be entertained.

## **TERMS AND CONDITION:**

### **8. Cost of tender document:**

The tenderer shall purchase the tender document from the Office of Water Works, Panbazar, Guwahati by paying Rs.2,000.00 (Rupees Two Thousand) only in cash as non-refundable tender document fees.

The Tender document is non transferable.

### **2. Earnest Money:**

The Tenderer shall, as a condition for consideration of the tender, furnish Earnest Money @ 2% on the Estimated Value (1% for S.C. & ST) by TDR/FDR in the prescribed format (*from Nationalized / Schedule Bank*) pledged in favour of "Commissioner, Guwahati Municipal Corporation, Guwahati for an amount specified in the Notice Inviting Tender. Earnest Money furnished by Demand Draft or by Bankers Cheque shall remain valid for a minimum period of 1 (*One*) Year from the date of opening of tender. Tender(s) without Earnest Money will be rejected.

The SC/ST Tenderer must submit the valid cast certificate along with the tender in support of his claim. Photocopy must be attested by a Gazetted officer.

In case of the Tenderer quoted rate above the Estimated rate / Amount and if his tender is accepted then tenderer is to deposit additional 2% earnest money for the additional amount over the estimated amount.

In case the Tenderer quoted rate beyond 10% below of the estimated rate he must deposit additional Earnest Money for that amount. (Example - If a contractor quoted 17% below the estimated amount he must deposit additional 7% Earnest Money. His total Earnest Money will be 2% + 7% = 9%).

The Earnest Money of the unsuccessful tenders shall be released without interest within one month from the date of finalization of award of contract or on expiry of the validity of tenders whichever is later.

The EMD may be forfeited in case the tenderer revoke or cancel his tender or vary any terms thereof within the validity period of tenders without the consent of GMC in writing or if the tenderer fails to complete contractual formalities such as formal acceptance of the order, sign the Contract, furnish Security Deposit within the time specified in the order.

### **3. Security Deposit:**

The full security deposit @ 10% of the work Value shall be deducted from the contractors Bill (*Running Bill or Final Bill*) and same shall be retained By G.M.C. for a period of one 1(*one*) Year. In that case, 2% E.M. as security would be released along with the final bill for the work. The security amount shall be released after 1(*one*) year of completion of the work subject to the condition that the work remain in proper condition to be certified by the concerned Engineer. Otherwise the security amount will be forfeited to G.M.C.

### **4. Duration:**

The selected tenderer must complete the work in all respect within the specified time and no incomplete work will be accepted and no payment for the same will be made.

**5. Instruction for construction period:**

The selected tenderer at own cost shall fix up a board at the work site from the day of starting till completion of the work with a sign board as follows-

<b>Name of Work:-</b>	2 nos. of raw water pump sets for Supply, Installation, Testing and Commissioning of electrical motor driven Horizontal Multistage (10 stage) centrifugal pump (220 H.P.) having efficiency not less than 73% with rated impeller dia not less than 271mm, coupled with TEFC squirrel cage foot mounted induction motor suitable for operation with 415 (+/- 10%) V, 3 phase power supply with star-delta starter at 2 <sup>nd</sup> Stage Pumping Station along with common distribution panel board under Kamakhya Water Supply Scheme.
Tendered Value:-	.....
Name of Contractor:-	.....

The selected tenderer at his own cost shall take photograph of the work as per direction of the Engineer in-charge of the work in three stages: -

- 9. Initial condition of the site of work with the signed board.
  - (ii) During construction
  - (iii) After completion of the work.

The three stage photographs should be taken at various locations in the same place as directed by the Engineer in-charge. No bill shall be paid without photographs.

For carrying out any work in Sunday, holiday or during night contractor will have to obtain permission from engineer in-charge. Otherwise for the work done without information, engineer in-charge shall have the discretion to accept or reject the same.

**10. Regarding Materials:**

No Materials will be supplied to the contractors from G.M.C. The contractor will have to arrange everything of their own and no extra payment will be made for the same. However a provision will stand to issue of the materials subject to availability of the stock and in that case cost will be deducted from contractors' bill as assessed from time to time.

For all materials, test certificate from competent authority must be provided as and when required by Engineer, In-charge.

Contractor shall be responsible for safe custody of their materials and GMC shall in no way, be held responsible for any damage / theft / loss of contractor's materials stored at the designated places.

**11. Commencement of Work:**

The contractor must start his work *within 7 (Seven) days* of handing over of the site, otherwise without prejudice to any of its rights or remedies, G.M.C. may terminate the contract and forfeit the earnest money.

**12. Completion of Work:**

The contractor must complete the work within the time frame as mentioned in the **NIT Clause** from the date of issue of the formal work order.

During execution of work if any type of construction found in the alignment of the work, that must be resolved by the selected tenderer at his own cost risk & responsibility. No extra payment will be made in any case.



### **13. Mode of Submission of Tender:**

The tender document shall be duly filled in, signed & stamped on each page by the tenderer and the complete set along with all documents and information complete as required shall be submitted under sealed covers within the due date, time and place as specified in the Notice Inviting Tender. The envelopes shall be super scribed with the name of work, full **Name, Address & Phone no.** of the tenderer and with a note "TENDER". The tender, complete in all respects, shall be submitted as mentioned below and addressed to:

THE COMMISSIONER,  
GUWAHATI MUNICIPAL CORPORATION,  
PANBAZAR, GUWAHATI -781001 (ASSAM)

Tender once submitted cannot be withdrawn after opening of tender.

Delayed / late offers due to any reason whatsoever and bids received in torn or open condition shall not be considered for opening and the same shall be returned as it is.

### **10. Quoting of Rate:**

The tenderer should quote their rates as per the format attached with the tender document for the work by filling in the rates & amounts, duly signed & stamped on each page and the same shall be put in separate sealed envelope Group wise and duly super scribing the envelope with the name of work. The rate shall not contain any exceptions / deviations / condition / presumptions of any kind. Any exceptions / deviations / conditions / presumptions made in the quoted rate shall either be ignored or the same shall make the tender liable for rejection.

The quoted price shall be inclusive of all taxes, duties, levies etc. as applicable and all expenses.

No escalation of rates will be allowed in any case within 1 (one) year from the date of opening of the tender.

The prices quoted by the bidder shall remain firm till completion of the works.

The intending tenderer shall be deemed to have visited the site and familiarized themselves thoroughly with the site conditions before submitting the tender. Non-familiarity with the site conditions will not be considered a reason either for extra claims or for not carrying out the works in strict conformity with the drawings and specifications.

### **11. Opening of Tenders:**

At the time of tender opening, GMC will allow only authorized representative of the tenderers. Tenderers are advised to depute representative duly authorized by them. Tenders will be opened on the same day after one hour of closing of the tender Box.

If the opening date of the tender falls on holiday or the office remains closed on the opening date, due to any reason, the tender will be open on the next working day at the same time.

### **12. (a) Evaluation of Tenders:**

The lowest rate will be considered on bid amount amongst the qualified tenderers shall be considered as the preferred tenderer subject to the price quote of the tenderer being nearest to the minimum benchmark price fixed by the evolution committee formed for evaluating the tenders. Any price quote lower than the minimum benchmark price fixed by the evaluation committee shall not be considered for selection. This minimum benchmark price shall not be disclosed. This minimum benchmark price shall be fixed by the evaluation committee after submission of the tenders by the last date of submission but before opening of tender to maintain transparency.

Though preference will be given to experienced and financially sound contractors, timely executing of work will be examined and on the basis of his earlier performance preference will be given. Estimate is prepared with GST.

**(b) Validity of Tenders:**

Tenders submitted by the tenderers shall remain valid for a minimum period of 6 (Six) months from the date of opening of tenders. The tenderers shall not be entitled, during the said period of six months without the consent in writing of GMC, to revoke or cancel their tenders or vary the tenders submitted or any term thereof. In case of bidder revoking or canceling his bid or vary any terms in regard thereof without the consent of GMC in writing, GMC shall forfeit their Earnest Money paid by them along with their bid.

The tenderers shall extend the validity of their tenders if so desired by GMC. In the event of such extension of validity of tenders, the tenderers shall extend validity of Earnest Money Deposit suitably, as required. Separate intimation in this regard, i.e. extension of validity of the EMD shall not be given to the tenderers and the tenderers will be required to extend such validity entirely on its own.

**13. PAN Card:**

The tenderer must have a valid PAN Card. Photo copy of which must be submitted along with the tender. It should be duly attested by a Gazetted Officer. I.T. will be deducted as per applicable rate from the bill.

**14. GST Registration:**

The tenderer must have a Valid GST registration no., photo copy of which must be submitted along with the tender. It should be duly attested by a Gazetted officer. GST will be deducted from the bill as per applicable rate.

**15. Experience in Similar Nature of Work:**

The tenderer must submit the Details of work of completed RELEVANT TO SIMILAR NATURE OF WORK. As per Form-1 of tender document. **As a proof, copies of work order and completion certificates indicating actual executed value and actual date of completion) shall be submitted by the bidders.** If necessary, additional sheet may be enclosed.

**Similar nature means:** - Supply and installation of pump set of not less than 150KW.

Credential certificate, issued by Govt. / Semi Govt. Urban Local Body, shall only be accepted for assessing the eligibility of a tenderer having following information

Name & Address of the Organization	Name & nature of work and location with work order no.	Awarded value (in Rs.)	Date of Commencement of work	Date of satisfactory completion of the work	Completion certificate and the final certified cost of the work

Certificate issuing officer of Govt. / Semi Govt. / Urban Local Body should not be less than the rank of Executive Engineer.

**16. Tools & Plants:**

All tools and plants (including power & water etc.) required for the works are to be arranged by the contractor at his own cost and risk. If any tools & plants are issued by department, the higher charge will be deducted from the bills as fixed by the department. Tenderer must submit the details of equipments available at his disposal as per Form-2.

**17. Variation of Estimated Quantity:**

Estimate quantity may slightly vary during execution according to site condition. Payment will be made as per measurement of actual work done at site.

**18. Canvassing:**

Canvassing directly or indirectly in any form in connection with the tender strictly prohibited. One, who resorts canvassing are liable for rejection.

**19. Right of GMC:**

The GMC authority reserved the rights to reject any or all tenders without assigning any reason thereof and does not bind itself to accept the lowest rate.

Tenders in which any of the particulars and prescribed information are missing or are incomplete in any respect and/or the prescribed conditions are not fulfilled are liable to be rejected. The tender containing unsolicited remarks or any additional conditions are liable to be rejected.

**20. Addenda / Corrigenda:**

Addenda / Corrigenda may be issued by GMC to the tender document prior to opening of tender to clarify documents or to reflect modification to the terms of tender document. All future addenda and corrigenda will be hosted in the website <http://gmcportal.in> as well as in office notice board.

Each tenderer shall attach a copy of each addendum/corrigendum along with the tender after signing a stamping on each page. All addenda / corrigenda shall form part of the tender document.

**21. Corrections in BID:**

All changes / alterations / corrections in the tender shall be signed by the person signing the tender and stamped.

Tenderer are advised to submit their tenders strictly on the terms, conditions, scope contained in the tender document and not to stipulate any deviations/exception.

Tenderer shall submit only one tender in one package. Submission of more than one tender/ alternative tenders including in association with other tenderer will not be accepted thereby making both.

**22. Scope of work:**

The work is related to 2 nos. of raw pump sets for Supply, Installation, Testing and Commissioning of electrical motor driven Horizontal Multistage (10 stage) centrifugal pump (200 H.P.) having efficiency not less than 73% with rated impeller dia not less than 271mm, coupled with TEFC squirrel cage foot mounted induction motor suitable for operation with 415 (+/- 10%) V, 3 phase power supply with star-delta starter at 2<sup>nd</sup> Stage Pumping Station along with common distribution panel board under Kamakhya Water Supply Scheme.. Detail specification of pump has been incorporated in the BOQ / estimate. For installation part also Board Guidelines has been incorporated in the BOQ. Tenderer has to consider all required materials (best quality) and labour charge for complete installation of the pump set to make it properly functional even if some component are not mentioned in the Board Guidelines. Tenderer are requested to consider all expanses and see the location before submitting tender.

### **23. Inspection :**

The selected party/ firm are to arrange inspection facility to the departmental representative/ Engineer during manufacturing of the pump & motor. Visiting representative/ Engineer must be afforded with facility to carry out their inspection. Necessary expenditure in this regard is to borne by the selected party/ firm. If for any reason the departmental representative/ Engineer unable to visit the pump manufacturing company, then inspection must be done through an approved third party and inspection report must be submitted to the department.

### **24. Location:**

Intake Point of Kamakhy Water Supply Treatment Plant is located on embankment river Brahmaputra.

### **25. Pumps Specifications**

#### **A. STANDARDS**

Except as otherwise specified all equipment and materials shall comply with the requirements of applicable latest editions of standards and code of practices of the Indian Standard Institution (ISI) or where ISI do not exist to British Standards (BS) should equipment/materials be offered to other standards, the equipment/materials shall be equal to or those specified and fill details of difference shall be furnished on separate sheet titled "Comparison of standards".

#### **B. GENERAL**

1. All materials incorporated in the work shall be the most suitable for the duty concerned and shall be new and of first class commercial quality, free from imperfections and selected for long life and minimum maintenance.
2. For electrical 'equipment, dissimilar metals shall not, as far as possible, lie in contact with each other. Where unavoidable, such material can be used. Provided the material potential difference between them does not exceed 250 MV.
3. Except as specified otherwise, the following material specification shall govern for electrical equipment or component of electrical equipment:
  - a) Outdoor/Indoor structural sheet: Hot dip galvanized in accordance with IS:2629.
  - b) Nuts, bolts, screws, washers and springs: steel components shall be cadmium/ zinc/chromium plated. Brass, phosphor bronze and other non-ferrous material shall be electro-tinned/chromium plated. Springs shall be of stainless steel or phosphor bronze.
  - c) Insulating materials, Class F or better.
  - d) Wood shall not be used except where specifically noted in the Enquiry Specification.  
MI flanges shall be drilled in accordance with equipment of IS: 1538.  
All flanges shall be flat faced and shall be full or spot faced on the back side.  
Castings and fabricated materials shall be finished smooth all over.  
  
All Carbon Steel fasteners used shall be electro-galvanized.

#### **C. QUALITY AND WORKMANSHIP**

All materials to be used should be new and of first class quality.  
The pump shall operate without excessive vibration and with minimum noise. All revolving parts shall be truly balanced.

#### **D. HORIZONTAL CENTRIFUGAL PUMP**

- **Design Requirements:**

- a) The pump shall be capable of developing the required total head at rated capacity.

- b) The pump should meet the system requirement. The tenderer should visit site and assess the total system requirement.
- c) The required NPSH at duty point shall be at least 1.0 M less than the available NPSH.
  - (i) The maximum power required by the pump from zero discharge to zero head.
  - (ii) 110% of the power required at the duty point, power required shall be worked out not considering 1% negative tolerance on the quote figure of the efficiency.

• **Features of Construction:**

- a) Pump & motor should be same make.
- b) One complete extra set of bearing of the each pump set in original is to be provided by company with the pump set.
- c) One set (one pair) of shaft sleeve in original to be provided by the company along with the each pump set.
- d) 10 kg. above quantity of gland packing each of the pump set have to be supplied.
- e) One digital flow meter have to be supplied along with the 2 nos. of pump sets.
- f) Single line drawing and B.O.M. for panel board should be submitted as per tender.
- g) Technical pump performance data and curve from the manufacturer must be submitted.
- h) List of technical persons with qualifications must be submitted along with the tender.
- i) Pumps of a particular category shall be identical and shall suitable for parallel operation with equal load division. Components of identical pumps shall be interchangeable.
- j) Impeller shall be enclosed type, securely keyed to the shaft. Means shall be provided to prevent loosening during operation including rotation in reverse direction.
- k) Pumps shall be provided with renewable type casing ring.
- l) The first critical speed of the pump rotor shall be at least 30 percent above the operating speed.
- m) Replaceable shaft sleeves shall be provided to protect the shaft where it passes through stuffing boxes.
- n) 1 (one) no. pressure meter of reputed company make to be supplied with each pump set.
- o) One no. pressure meter of reputed company make to be supplied with each pump set.
- p) Stuffing boxes shall be of such design that they can be repacked by removing the gland and lantern ring.
- q) Pump shall be provided with anti-friction bearings/hush bearings.
- r) Pump shall be furnished complete with flexible coupling.
- s) The base plate for pump and motor shall be common. Suitable holes shall be provided for grouting foundation bolts shall be complete with nuts and washers.
- t) Suction and discharge connections shall be flanged.
- u) Pump impeller shall be properly balanced.
- v) All accessories required for proper and safe operation shall be furnished with the pump.

Materials of construction

**Specification of pump**

- i. Make : Kirloskar/ Equivalent Brand
- ii. Total Head : 200M
- iii. Discharge : 180cu.m./hr.
- iv. Speed : 1486 Rpm
- v. Efficiency : Minimum 73%
- vi. Impeller dia : 271mm
- vii. Pump input (KW) : 134

**MOC**

- i. Casing : CI
- ii. Impeller : CF8M
- iii. Shaft : SS410
- iv. Sleeve : SS410
- v. Packing : Gland Packing

**Specification of Motor:**

- i. Make : Kirloskar/ Equivalent Brand
- ii. Rating : 160KW
- iii. Efficiency Class : IE2
- iv. Rpm : 1500

**Specification of Starter:**

- i. Make : Havel's/L&T

**Installation, testing, commissioning of the pump set**

Suction & delivery of the MS pipe line of the required size for fitting fixing with the pump set along with switch valve, non return valve in the line.

Foundation with RCC concrete M-20 from the original soil with fitting fixing with the base france.

**Distribution Panel Board:**

14. Supply of Distribution Panel Board (common for 2 new sets + existing 220HP pump set) (MCCB, MCB, V. Meter, A. Meter, copper busbar, Capacitor Bank, selector switch, required size copper cable from anel to starter and to motor etc.)

**Installation of Distribution Panel Board:**

Installation of Distribution Panel Board including testing commissioning (common for 2 new sets + existing 220HP pump set)

(MCCB, MCB, V. Meter, A. Meter, copper busbar, Capacitor Bank, selector switch, required size copper cable from anel to starter and to motor etc.)

**26.Operational Guarantee:**

After commissioning & testing the machineries the selected tenderer will have to take guarantee of the work for one year. Including required discharge of the pump set must shows in every quarterly during the guarantee period otherwise the Earnest Money would be retained until and unless to do so. Any defect arises during one year will have to be rectified by the tenderer at his own cost.

**27. Arbitration:**

Any dispute or difference arising out during execution of work which cannot be amicably settled within 30 days including those considered as such by only one of the parties, shall be finally settled at Guwahati Development Department of Govt. of Assam under the provision of India Arbitration and conciliation Act 1996 and the rules made there under amended from time to time. The decision of the Arbitration shall be final and binding on both the parties. The resulting award shall be in lieu of any other remedy other works those are not related to arbitration shall not be hampered during the process of Arbitration.

**DOCUMENTS, INFORMATION TO BE SUBMITTED WITH TENDER:**

1. Complete tender document including all annexure and forms duly filled in, signed and putting seal on each page.
2. Earnest Money deposit as per NIT.
3. Details of work of completed RELEVANT TO SIMILAR NATURE OF WORK. As per Form-1 of tender document. As a proof, copies of work order and completion certificates indicating actual executed value and actual date of completion) must be submitted by the bidders.
4. Details of construction plant and equipments available in Form-2 of the tender document which the tenderer proposed to use for this work
5. Information about tenderer.
6. Photo copy of GST registration / clearance certificate duly attested by a Gazetted Officer.
7. Photo copy of PAN card (duly attested by Gazetted officer).
8. Photo copy of valid cast certificate (*in case of SC & ST tenderer*) along with the tender duly attested by a Gazetted officer.
9. Any other information /document required as per tender document.

**NOTIFICATION OF AWARD OF CONTRACT, AGREEMENT ETC.**

In case the tender is accepted, GMC will notify the successful tenderer by issuing a Preliminary work order in writing. The Tenderer shall have to accept the PWO and require to submit the contract agreement in F2 form along with other terms and condition as per NIT in duplicate within the time specified therein after signing and putting seal on each page as a token of acceptance of the award and execute the contract within the stipulated time. Completion period shall, however, be counted from the date of issue of Formal work order.

The Selected tenderers will have to sign a formal tender agreement with the Commissioner G.M.C. in GMC's F2 form of Agreement in addition to clause mentioned in the tender document.

Failure of the tenderer bidder to comply with the requirements of this article shall constitute sufficient grounds for termination of the order/contract and forfeiture of the Earnest Money Deposit.

The whole work may be split up between more than one contractor or may be accepted in part at the discretion of GMC. Quoted rates should hold good for such eventualities.

Contractor shall be responsible for safe custody of their materials and GMC shall in no way, be held responsible for any damage/theft/loss of contractor's materials stored at the designated places.

Sd/-  
Commissioner,  
Guwahati Municipal Corporation,  
Guwahati.

**CONTRACTOR'S BID**

To,

The Commissioner,  
Guwahati Municipal Corporation, Guwahati,  
Panbazar, Guwahati.  
Assam -781 001.

SUB:- 2 nos. of raw water pump sets for Supply, Installation, Testing and Commissioning of electrical motor driven Horizontal Multistage (10 stage) centrifugal pump (200 H.P.) having efficiency not less than 73% with rated impeller dia not less than 271mm, coupled with TEFC squirrel cage foot mounted induction motor suitable for operation with 415 (+/- 10%) V, 3 phase power supply with star-delta starter at 2nd Stage Pumping Station along with common distribution panel board under Kamakhya Water Supply Scheme.

Ref: - Detailed Tender Notice no GWS/..... dt. ....

Sir,

Having examined the bidding documents, I / We offer to execute the works described above in accordance with the Conditions of Contract, Specifications, Drawing and Bill of Quantities accompanying this Bid for the Contract Price of ..... [in figures]  
..... [in letters].

This Bid and your written acceptance of it shall constitute a binding contract between us. We understand that you are not bound to accept the lowest or any Bid you receive.

I / We hereby certify that I / We have taken steps to ensure that no person acting for us or on our behalf will engage in bribery.

I / We also undertake that, in completing for (and, if the award is made to us, in executing) the above contract, I/ We will strictly observe the laws against fraud and corruption in force in India namely "Prevention of Corruption Act 1988".

I / We Undertake, if our tender is accepted, to commence the works as soon as is reasonably possible after the receipt of notice to commence, and to complete the whole of the works comprised in the Contract within the time stated in NIT.

I / We agree to abide by this tender and it shall remain binding upon us.

I / We hereby confirm that this Bid complies with the Eligibility, Bid Validity and Bid Security (E.M.) required by the Bidding documents.

I / We understand that you are not bound to accept the lowest or any tender you may receive.  
Dated this ..... day of .....

Yours faithfully,

Authorised Signature:-

Name & Title of Signatory:-

Full Name of Bidder (IN BLOCK LETTER):-

Address:-

N.B. Overwriting will be out rightly rejected



## CHECK LIST

Please tick  in appropriate box

Yes      No

1. All pages of document signed	<input type="checkbox"/>	<input type="checkbox"/>
2. Tender Document Fee	<input type="checkbox"/>	<input type="checkbox"/>
3. E.M. in shape of Bank Draft / Call Deposit	<input type="checkbox"/>	<input type="checkbox"/>
4. Photocopy of PAN Card	<input type="checkbox"/>	<input type="checkbox"/>
5. Rate quoted as per format	<input type="checkbox"/>	<input type="checkbox"/>
6. Experience Details (Form-1) Submitted with experience certificate from respective department.	<input type="checkbox"/>	<input type="checkbox"/>
7. Equipment Detail (Form-2)	<input type="checkbox"/>	<input type="checkbox"/>
8. Audited Balance Sheet indicating Annual Turn Over for the year	<input type="checkbox"/>	<input type="checkbox"/>
a. 2014 - 2015	<input type="checkbox"/>	<input type="checkbox"/>
b. 2015 - 2016	<input type="checkbox"/>	<input type="checkbox"/>
c. 2016 - 2017	<input type="checkbox"/>	<input type="checkbox"/>
9. Solvency Certificate	<input type="checkbox"/>	<input type="checkbox"/>

## Information About Tenderers

(To be furnished with Tender)

### 1. In case of Individual:

- 1.1. Name of business :
- 1.2. Whether his business is registered. :
- 1.3. Date of commencement of business. :
- 1.4. Whether he pays Income Tax :
- 1.5. Age of the tenderer :

### 2. In case of Partnership firm:

- 2.1. Names & ages of Partners :
- 2.2. Whether the Partnership is registered. :
- 2.3. Date of establishment of firm :
- 2.4. If each of the partners of the firm pays income tax or not, who of them pays the same. :

### 3. In case of Limited Liability Company:

Company or Company Limited by Guarantees

- 3.1. Amount of paid up capital :
- 3.2. Name of Directors :
- 3.3. Date of Registration of Company. :
- 3.4. Annual Reports /Copies of audited Balance Sheets of the Company of the last three years. :

4. PAN of Tenderer :

*Signature of Tenderer*  
*Name and Address of the tenderer.*

# **FORM-1**

## **EXPERIENCE DETAILS**

**DETAILS OF SIMILAR WORKS COMPLETED BY THE TENDERER IN THE LAST 3 (THREE) YEARS.**

<b>Sl. No.</b>	<b>Full particulars of work carried out by the tenderer</b>	<b>Value of contract</b>	<b>Completion time as stated in the tender</b>	<b>Actual date of completion</b>	<b>Actual Executed Value</b>	<b>Name and Postal Address of Client</b>

Copy of work order (s), Completion Certificate etc. in support of the above are attached.

**[ Signature of Tenderer ]**

**Name and Address of the Tenderer**

## FORM - 2

### EQUIPMENTS DETAILS AT THE DISPOSAL OF TENDERERS.

MACHINERIES	NUMBER	MAKE	CAPACITY	OWNED	HIRED
1. Electrical Welding machine					
2. Generator set					
3. Pipe Wrench of difference size					
4. Chain ton of difference size					
5. Pulling & lifting machine.					
6. Different machine for electrical checking					
7. Any other machine related to fitting fixing of pump set and different size pipes (please specify)					

[Signature of Tenderer]

Name and Address of the Tenderer